

TELANGANA STATE POWER GENERATION CORPORATION LIMITED
KAKATIYA THERMAL POWER PROJECT/CHELPUR

To
The Principal,
DAV High School,
KTPP, Chelpur.

Date: 04.12.2023
Place: KTPP, Chelpur

Sir,

SUB: KTPP- II - Chemical Division-submission of Drinking Water Sample
Test Results – Received from DAV High School - Reg.

---x---

It is herewith furnishing the Drinking water sample results which were received from DAV High School, KTPP Colony, Chelpur on dt: 04.12.2023.

At DAV High School, KTPP, Chelpur.	Parameters	pH	Λ	P-alk	M-alk	TH	CaH	MgH	Cl ⁻	Silica	Turbidity	Res.Cl ₂
	units		$\mu\text{s/cm}$	ppm	ppm	ppm	ppm	ppm	ppm	ppm	NTU	ppm
	Results	8.15	505	NIL	166	170	80	70	40	12.54	1.98	0.1

Note: The drinking water is safe for drinking purpose.

Chief Chemist (I/C)


KTPP STAGE IV
Chief Chemist
Kakatiya Thermal Power Project
Chelpur-506179
Dt: Jayashanker Bhupalpally